

Questions and Answers

11-108 Mobile Storage System

1. Specifications state that fixed carriages should be of same construction as mobile carriages. Drawing states that fixed shelving will be sitting directly on floor. Is a fixed carriage wanted for fixed shelving or is it to sit directly on the floor?

IN THE DRAWING SHELVES NUMBERED 1 & 9 ARE TO BE FIXED SHELVING THAT SIT DIRECTLY ON THE FLOOR, SHELF 8 CAN BE MOBILE OR FIXED SHELVING (IF FIXED, THEN SIT DIRECTLY ON FLOOR).

2. Specifications states that there will be (7) movable carriages 12'L x 24"D and shelving will there be (24) sections of 76"H x 48"W x 24D and (8) sections 88"H x 48"W x 12"D. The drawing shows (7) carriages 12'L x 24"D which equals (21) units of shelving. This shelving is noted on the drawing to be 84"H with 7 openings. The drawing also shows 2 rows of shelving 16'L and is listed as 88"H with 8 openings. Do we go by the specifications of the drawing?

YES

3. Which is wanted for the ends of the movable shelving to cover mechanical assist tower: Laminate end panels or a painted steel chain drive cover?

GIVE QUOTE FOR BOTH

4. 5" wheels are specified. Will 3" wheels be allowed so long as the carriage can hold 1,000 lbs per linear foot?

YES