

Questions and Answers
11-171 Intercom System and Installation

I just want to clarify that this is only an intercom system at the specified locations. This does not include any general paging or interaction with existing telephone systems, correct?

Also, does St. Charles County have any specific manufacturer requirements? I did not see any listed.

If I understand his first question correctly, the answer is no, it cannot be tied into the existing phone, except that it should have the capability to be dialed into for remote paging (Facilities wants to be able to page from their office in the case of emergencies). As far as manufacturer, we looked at the On-Q system because we like its capabilities; however, if there is a comparable system, we have no problems with it.
